

# Installation

# S19-120T

**Drench Shower - Horizontal Supply** 

#### **Table of Contents**

| Safety Information     | 2 |
|------------------------|---|
| Supplies Required      | 3 |
| Assemble Components    | 3 |
| Connect Water Supply   | 3 |
| Assembly of Components | 4 |
| Parts List             |   |




Read the instructions in this manual before beginning installation. Save these instructions and refer to them for inspection, maintenance and troubleshooting information.

For questions regarding the operation, installation or maintenance of this product, visit bradleycorp.com or call 800.BRADLEY (800.272.3539).

Product warranties and parts information may also be found under "Products" on our web site at bradleycorp.com.

215-148CP Rev. R: ECO 19-05-034A © 2021 Bradley Page 1 of 4 2/15/2021





S19-120T Installation

# **Safety Information**

#### To ensure proper operation:

#### Installation

This fixture has been designed and 3rd party tested to meet ANSI/ISEA Z358.1. The system must be tested periodically to be sure it is functioning properly to meet the standard. Please refer to the ANSI/ISEA Z358.1 standard on testing requirements.

The installation, maintenance and location of all safety drench showers, eye and eye/face washes must comply with the requirements of ANSI/ISEA Z358.1. Workers who may come in contact with potentially hazardous materials should be trained regarding the location and proper operation of emergency equipment per ANSI/ISEA Z358.1.

ANSI/ISEA Z358.1 requires this unit to be used with a clean, potable, uninterrupted supply of tepid water. Bradley plumbed emergency fixtures require a minimum of 30 psi flowing pressure in order to function as designed and meet the ANSI/ISEA Z358.1 standard.

Before installation make sure that this equipment will meet the requirements of the potential hazardous contaminants in your location.

Installation of this system must be completed by a qualified plumber in compliance with all national and local codes. Compliance and conformity to drain requirements and other local codes and ordinances is the responsibility of the installer.

#### **Weekly Inspections**

To ensure all emergency shower and eye/face wash fixtures are ready to be used when needed, regular checks and maintenance must be conducted. Weekly inspections must be conducted on all safety equipment to make sure a suitable flushing fluid supply is present and to make sure the equipment is in good operating condition.

#### **Water Temperature**

ANSI/ISEA Z358.1 requires tepid water. Suitable range is 60°F to 100°F (16°C to 38°C). Personal injury is possible outside this temperature range.

## **Supplies Required**

- · Pipe sealant and teflon tape
- · Piping to 1" NPT water supply inlet
- · Adequate supply pipe supports
- Minimum 4" (102 mm) drain to accommodate 30 gallons (115 liters) per minute discharge for shower waste
- Sign-mounting hardware



Local codes may require the installation of a backflow prevention valve to complete proper installation. Backflow prevention valves are not included with the fixture and may be supplied by the contractor or purchased from Bradley Corporation.


## **Assemble Components**

- 1. Assemble components as shown on page 4.
- Apply pipe sealant or tape (by installer) to all male-threaded pipe joints.
- 3. Bottom edge of showerhead should be 7'-0" (2134 mm) from the floor.

# **Connect Water Supply**


NOTICE! Do not rely on Bradley's Drench Shower to support supply piping.

- Connect water supply piping to 1" NPT inlet on unit (piping supplied by installer). Provide adequate supports (supplied by installer) for supply pipe using pipe hangers or other means.
- Mount the safety sign to the wall using sign-mounting hardware supplied by installer.
- 3. Open water supply lines. Test for leaks and adequate water flow.



S19-120T Installation

# **Assembly of Components**



# **Parts List**

| Item | Part No. | Qty. | Description                      |
|------|----------|------|----------------------------------|
| 1    | S30-059  | 1    | Stay-Open Ball Valve<br>Assembly |
| 1.1  | S27-278  | 1    | 1" Ball Valve with Jam Nut       |
| 1.11 | 110-214  | 1    | Jam Nut only                     |
| 1.2  | 124-048  | 1    | Washer, Friction                 |
| 1.3  | 153-489  | 1    | Adapter                          |
| 1.4  | 128-201  | 1    | Handle                           |
| 2    | 128-156A | 1    | Pull Rod                         |
| 3    | 151-001  | 2    | Curtain Hook                     |
| 4    | 113-594  | 1    | Pipe 1" NPT x 12"                |

| Item | Part No. | Qty. | Description  |
|------|----------|------|--|
| 5    | 169-1073 | 1    | 90° Elbow NPT  |
| 6    | S24-189  | 1    | Plastic Showerhead and<br>Stainless Steel Shroud<br>Assembly |
| 6.1  | S24-193  | 1    | Shroud Assembly  |
| 6.11 | 187-053  | 1    | Showerhead Shell   |
| 6.12 | 154-147  | 1    | Ring   |
| 6.2  | S24-188  | 1    | Plastic Showerhead Assembly                                  |
| 7    | 114-050  | 1    | Safety Sign  |
| 8    | 204-421  | 1    | Emergency Inspection Tag                                     |